

July 19, 2019

Addendum 2


To: Irrigation Contractors and Suppliers

Re: Five Ponds Golf Course Irrigation Project (CN 2019-06)

The following are changes, clarifications or responses to questions raised during the Five Ponds Golf Course irrigation project bid process.

1. Bids remain due on July 25, 2019 before 11:00 am EDT.
2. Warminster Township is in the process of securing stream crossing permits for the four crossings and will pay permit fees.
3. Pipe crossing gas easements (three locations) are to be installed in DR13.5 HDPE pipe sleeving that is two sizes larger than the irrigation pipe (10" sleeve for 6" pipe, 12" sleeve for 8" pipe).
4. Bidders are to comply with all aspects of the Responsible Building Contractor Code in Appendix A of the Project Manual, including the apprenticeship program outline in Section 4-102.3.K of Appendix A.

Hydro Designs, Inc.



Paul C. McMahon

